

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-1402:0108

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: TELULAR CORP2727 Paces Ferry Rd., Suite 1-800, Atlanta, GA 30339
Contact: Raj Kosaraju (678) 264-2012 Fax (678) 264-2062
Email: rkosaraju@telular.com

DESIGN: Models TG7G0002, TG7G0003, TG7GA002, TG7GA003, and TG7GFS03 digital cellular radio alarm transmission system for fire/burglar alarm system control units.

Models TG7G0002 and TG7G003 consisting of subassembly models TGKIT001 and 77016100 standard enclosure. Models TG7GA002, TG7GA003, consisting of subassembly models TGKT001 and 77013500 attack resistant enclosure, communicator system.

Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. The fire alarm control unit and units must be installed in the same room. For indoor use only.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as a digital cellular radio alarm transmission device to provide a primary transmission path (cellular) for connection to a listed compatible fire and burglar alarm control unit with integral digital alarm communicator transmitter (DACT). Models TG7G0002 and TG7G0003 are intended for residential application. Models TG7GA002, TG7GA003, and TG7GFS03 are intended for residential and commercial applications. Refer to listee's Installation Instruction Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

02-09-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division